



City of University Park

IRRIGATION (LAWN SPRINKLERS)

General Outline For Plan Submittal

1. Two (2) complete sets of drawings sealed by a State of Texas licensed irrigator are required for plan review. The drawings shall include the following:
 - a. The location of the water meter, isolation valve, y-strainer, double check, and main valve.
 - b. Indicate that the system is equipped with a freeze switch and rain sensor.
 - c. List all sprinkler head types and locations.
 - d. All parkways and landscape areas less than 48" wide and adjacent to impermeable surfaces shall be equipped with drip irrigation.
 - e. Major physical features and the boundaries of the areas to be watered.

Note: Ditches shall remain uncovered enough to allow inspection of the primer on joints and inspect the meter, valves, strainer, and double check assembly.

*******NOTE: BACKFLOW TEST REPORTS SHALL BE
SUBMITTED TO THE BUILDING INSPECTION DEPARTMENT PRIOR
TO FINAL INSPECTION *******

